



# FAX TRANSMITTAL

DATE: January 31, 2003

CDC JOB NUMBER: New

DOCUMENT NUMBER: CDC-JB-002

DALLAS

FORT WORTH

LOS ANGELES

LAS VEGAS

CHICAGO

BALTIMORE

NEW ENGLAND

HONG KONG

MONTERREY

MONTREAL

COMPANY: American Limestone Company

FAX NUMBER: 214-747-2639

FROM: Jeff Bayer

TOTAL PAGES: 1, including this sheet

RE: Aluminum Stone Anchors

CDC recommends your aluminum anchors be coated with Kynar paint even though the anchors are 6000 series aluminum and exhibit excellent corrosion - resistance without any coating. Kynar is an organic coating based on polyvinylidene fluoride resins and have exhibited excellent weatherability since its development 40 years ago. By painting the aluminum, American Limestone Company is certain the stone anchors will long exceed the anticipated lifespan of the building.

It is not necessary to paint the edges of the aluminum where the extrusions have been cut to length nor is it necessary to paint where holes have been drilled for fasteners. Aluminum alloys are inherently corrosion-resistant by the formation of a protective oxide film when exposed to air. The small surface areas exposed will not hamper the performance of the anchor.

Sincerely,

Jeff Bayer, P.E.  
Principal  
CDC, Inc.

7502 Greenville Ave.  
Suite 800  
Dallas, Texas  
75231 USA  
tel. 972/437-4200  
fax. 972/437-4562  
general@cdc-usa.com

If you do not receive a clear, complete transmission, please call 972/437-4200.

**AMERICAN LIMESTONE COMPANY**  
A TEXAS CORPORATION  
WWW.AMERICANLIMESTONE.COM  
INFO@AMERICANLIMESTONE.COM

CDC LETTER – ALUMINUM STONE ANCHORS

4.2.3